

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance**0432-CPR-00007-16**

(Version: 01)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Locks "OneSystem Standard Panic" narrow style**Mechanically operated locks for use on fire/smoke compartmentation doors**

as detailed and classified on appendix 1,

placed on the market under the name or trade mark of

ASSA ABLOY Sicherheitstechnik GmbHBildstockstr.20
D - 72458 Albstadt

and produced in the manufacturing plant(s)

DO 22.0

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)


EN 12209:2003/AC: 2005

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 18.04.2016 and will remain valid until 18.04.2021 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 18.04.2016


Dipl.-Ing. J. Jessen
Certification Manager Department 22

This Certificate consists of 1 page and 1 annex

The original of this document was issued in German language.
In case of doubt only the German version is valid.



Locks "OneSystem Standard Panic" narrow-style

Essential characteristics	Requirement clauses in EN 12209: 2003/AC: 2005	Performance
Self-closing ability	5.4.2 Closing force 5.1.2 re-latching force of latch bolt	Grade 6: (300 kg door mass, max. 25 N closing force) passed ≥ 2,5N: passed
Durability of self-closing action	5.3. Durability of latch action	Grade S: (200.000 cycles, 50 N side load on latch bolt) passed
Ability to maintain door in closed position, and not contribute to the spread of fire	5.5 Suitability for use on fire / smoke doors + annex A	Grade 1: passed
Control of dangerous substances	5.1.1 Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, following claim is suggested: Pass: the material in the lock do not contain or release any dangerous substance of maximum levels specified in existing European material standards or any national regulations

Product description

Item No.	Backset	Distance	Forend width	Classification
N 1600	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1601	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1602	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1603	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1604	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1605	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1606	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1607	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1608	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1609	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1610	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1611	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1612	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1613	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1614	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0
N 1615	30 bis 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 1 0 F 2 B A 2 0